

STUDY BENCH OF A CONTROL VALVE



Non contractual photo

SERVICE: 230 V, 50 HZ, 250 W COMPRESSED AIR: 6 BAR, 3 NM3 / H CLEAN WATER: 4 BAR, 20 ° C, 1000 L / H. DIMENSIONS: 850 X 425 X 940 MM **REFERENCE: MP135**

This bench allows the study of the characteristics of a regulating valve with pneumatic servomotor with needle. The concepts of CV and Kvs will be discussed. The valve will be used with or without positioner.

A pneumatic servomotor valve is supplied via the water supply via a needle valve. The flow is measured by a float flow meter. An expansion valve adjusts the pressure of the supply network. The pressure difference between upstream and downstream of the control valve is measured using a differential pressure transmitter with local display.

The influence of the positioner on the response of the valve is determined by means of a current generator (4 to 20 mA) allowing the actuator of the control valve to be controlled via an I / P converter or via an electro- pneumatic positioner.

The device is mounted on a welded stainless steel frame.

Educational Objectives:

- Determination of the experimental Kvs of the valve with and without positioner.
- Drawing and study of the curves:
- Intrinsic characteristics of the valve Qv = f (control) with constant pressure drop.
- Characteristic of the installed valve: Qv and ?P = f (control).
- Role of the positioner and hysteresis phenomenon.

Technical specifications:

It's made of:

- A regulator of the water supply circuit with manometer.
- A needle flow control valve made of stainless steel.
- Pneumatic control valve with variable CV in stainless steel.
- An electro-positioner.
- A regulator, air de-oiler with manometer.
- Differential pressure transmitter with local display and purge manifold.
- A float flowmeter
- An electrical box, waterproof IP 55, including:
- · A lockable disconnector,
- · A power-on LED,
- An emergency stop key.
- A current generator (4 to 20 mA) with potentiometer and indicator,
- The control signal is brought back to secure cards.